



Termination Cap Locations

Dimension Descriptions

A =	Clearance above the ground, a veranda, porch, deck or balcony - 12 inches (30cm) minimum	K. =	Clearance to mechanical air supply inlet - 6 feet (1.8 m) minimum
B =	Clearance to window or door that may be opened - 9 inches (30cm) minimum.	L+ =	Clearance above a paved sidewalk or paved driveway located on public property - 7 feet (2.1m) minimum
D* =	Vertical clearance to ventilated soffit located above the terminal within a horizontal distance of 2 feet (60 cm) from the center line of the terminal - 18 inches (46cm) minimum.	M# =	Clearance under veranda, porch, deck or balcony - 12 inches (30cm) minimum.
E* =	Clearance to unventilated soffit - 12 inches (30cm) minimum.		
F =	Clearance to outside corner - 6 inches as tested.	+	A vent must not terminate directly above a sidewalk or paved driveway which is located between two single family dwellings and serves both dwellings
G =	Clearance to inside corner - 6 inches as tested.	#	Only permitted if veranda, porch, deck or balcony is fully open on a minimum of 2 sides beneath the floor
H. =	Not to be installed above a meter regulator assembly within 3 feet (90cm) horizontally from the center-line of the regulator	.	As specified in Installation Codes. Note: Local codes or regulations may require different clearances
I =	Clearance to service regulator vent outlet - 3 feet (90cm) min. - United States; 6 feet (1.8m) min. - Canada	.	Distance required for vinyl soffit - 30 inches (76 cm) minimum. Distance required for vinyl soffit materials with the use of a vinyl siding shield - 18 inches (46 cm) minimum
J =	Clearance to non-mechanical air supply inlet to building or the combustion air inlet to any other appliance - 12 inches (30cm) minimum		